

Cooling mode:

(*)If C_{dc} is not determined by measurement, then the default degradation coefficient of heat pumps shall be 0.25.

Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.

Heating mode:

Where information relates to multi-split heat pumps, xthe test result and performance data may be obtained on the basis of performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.