

## Erp information

**KMF-180 DTR6** T2 Cooling mode:

Information requirements for air-to-air conditioners								
Model(s): KMF-180 DTR6 Test matching indoor units form, ducted: 4×								
Outdoor side heat exchanger of air conditioner: air								
Indoor side heat exchanger of air conditioner: air								
Type: compressor driven								
Driver of compressor: electric motor								
Item	Symbol	Value	Unit		Item	Symbol	Value	Unit
Rated cooling capacity	$P_{rated,c}$	17.50	kW		Seasonal space cooling energy efficiency	$\eta_{s,c}$	281.0	%
Declared cooling capacity for part load at given outdoor temperatures $T_j$ and indoor 27/19°C (dry/wet bulb)					Declared energy efficiency ratio or gas utilisation efficiency /auxiliary energy factor for part load at given outdoor temperatures $T_j$			
$T_j=+35^\circ\text{C}$	$P_{dc}$	17.50	kW		$T_j=+35^\circ\text{C}$	$EER_d$	2.71	--
$T_j=+30^\circ\text{C}$	$P_{dc}$	12.63	kW		$T_j=+30^\circ\text{C}$	$EER_d$	4.70	--
$T_j=+25^\circ\text{C}$	$P_{dc}$	8.15	kW		$T_j=+25^\circ\text{C}$	$EER_d$	8.68	--
$T_j=+20^\circ\text{C}$	$P_{dc}$	4.41	kW		$T_j=+20^\circ\text{C}$	$EER_d$	15.81	--
Degradation co-efficient for air conditioners(*)								
	$C_{dc}$	0.25	--					
Power consumption in modes other than "active mode"								
Off mode	$P_{OFF}$	0.005	kW		Crankcase heater mode	$P_{CK}$	0.002	kW
Thermosat-off mode	$P_{TO}$	0.002	kW		Standby mode	$P_{SB}$	0.005	kW
Other items								
Capacity control	variable				For air-to-air air conditioner: air flow rate, outdoor measured	--	5500	m <sup>3</sup> /h
Sound power level, outdoor	$L_{WA}$	73	dB					
GWP of the refrigerant		675	kg CO <sub>2</sub> eq (100years)					
Contact details								
(*)If $C_{dc}$ is not determined by measurement, then the default degradation coefficient of heat pumps shall be 0.25.								
Where information relates to multi-split air conditioners, the test result and performance data may be obtained on the basis of performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.								

## KMF-180 DTR6 T2

Heating mode:

Information requirements for heat pumps							
Model(s): KMF-180 DTR6 Test matching indoor units form, ducted: 4×							
Outdoor side heat exchanger of air conditioner: air							
Indoor side heat exchanger of air conditioner: air							
If the heater is equipped with a supplementary heater: no							
Driver of compressor: electric motor							
Parameters shall be declared for the average heating season, parameters for the warmer and colder heating seasons are optional.							
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heating capacity	$P_{rated,h}$	17.50	kW	Seasonal space heating energy efficiency	$\eta_{s,h}$	189.0	%
Declared heating capacity for part load at indoor temperature 20°C and outdoor temperatures $T_j$				Declared coefficient of performance or gas utilisation efficiency/auxiliary energy factor for part load at given outdoor temperatures $T_j$			
$T_j=-7^\circ\text{C}$	$P_{dh}$	9.73	kW	$T_j=-7^\circ\text{C}$	$COP_d$	2.77	--
$T_j=+2^\circ\text{C}$	$P_{dh}$	5.92	kW	$T_j=+2^\circ\text{C}$	$COP_d$	4.64	--
$T_j=+7^\circ\text{C}$	$P_{dh}$	4.02	kW	$T_j=+7^\circ\text{C}$	$COP_d$	6.68	--
$T_j=+12^\circ\text{C}$	$P_{dh}$	3.61	kW	$T_j=+12^\circ\text{C}$	$COP_d$	9.33	--
$T_{biv}$ =bivalent temperature	$P_{dh}$	11.00	kW	$T_{biv}$ =bivalent temperature	$COP_d$	2.34	--
$T_{OL}$ =operation temperature	$P_{dh}$	11.00	kW	$T_{OL}$ =operation temperature	$COP_d$	2.34	--
Bivalent temperature	$T_{biv}$	-10	°C				
Degradation co-efficient for heat pumps(**)	$C_{dh}$	0.25	--				
Power consumption in modes other than "active mode"				Supplementary heater			
Off mode	$P_{OFF}$	0.005	kW	Back-up heating capacity(*)	$e_{lbu}$	0	kW
Thermosat-off mode	$P_{TO}$	0.010	kW	Type of energy input			
Crankcase heater mode	$P_{CK}$	0.002	kW	Standby mode	$P_{SB}$	0.005	kW
Other items							
Capacity control	variable			For air-to-air heat pump: air flow rate, outdoor measured	--	5500	m <sup>3</sup> /h
Sound power level,outdoor	$L_{WA}$	73	dB				
GWP of the refrigerant		675	kg CO <sub>2</sub> eq (100years)				
Contact details							
(*)							
(**)If $C_{dh}$ is not determined by measurement, then the default degradation coefficient of heat pumps shall be 0.25.							
Where information relates to multi-split heat pumps, xthe test result and performance data may be obtained on the basis of performance of the outdoor unit, with a combination of indoor unit(s) recommended by the manufacturer or importer.							